

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC POOL AND BATHING PLACE
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-60-00130
Name of Facility: Silver Creek Homeowners Association
Address: 3291 Silverado Road
City, Zip: Green Cove Springs 32043

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Pool > 25000 Gallons
Owner: The Cam Team Inc
Person In Charge: The Cam Team Inc Phone: (904) 278-2338
PIC Email: gcabral@agentlink.net
Pool Operator: The Cam Team Inc Phone: (904) 278-2338

Inspection Information

Purpose: Reinspection
Inspection Date: 2/7/2022

Begin Time: 03:00 PM
End Time: 03:45 PM

Additional Information

22. Free Chlorine	3	VOLUME	83208
23. pH	7.6	POOL LOAD	90
24. Chlor. Stabilizer	40	FLOW RATE	450
33. Flowmeter	400	NIGHT SWIM	No
34. Thermometer		FILTER TYPE	CV

Items checked are not in compliance with Chapter 386 or 514, Florida Statutes, or Chapter 64E-9 or 64E-10, Florida Administrative Code. These violations must be corrected by the date indicated to avoid closure, administrative fines, or other legal actions. Florida Building Code (FBC) violations are reported to the local building official, and depending upon risk severity, the Department of Health may close the pool or rescind the operating permit.

Violation Markings

POOL AREA	17. Rules Posted	32. Vacuum Cleaner-FBC
1. Water Clarity/Algae Control	18. Certification	33. Flowmeter
2. Deck/Walkways	SANITARY FACILITIES	34. Thermometer
3. Tile/Pool Finish	X 19. Supplies 64E-10, FAC	35. Pressure/Vacuum Gauge
4. Depth Markers-FBC	X 20. Clean 64E-10, FAC	36. Equip. Room
5. Handrail/Ladder-FBC	WATER QUALITY	37. Cross Connection
6. Step Markings-FBC	21. Approved Test Kit	38. Gas Chlorine Eq.-FBC
7. Suction Outlets-514.0315(1)	22. Free Chlor./Brom.	39. Waste Water - FBC
8. Gutter Grates/Skimmer-FBC	23. pH	40. D.E. Separator-FBC
9. Lighting	24. Chlor. Stabilizer	41. Other Equipment
10. No Dive Markings-FBC	25. Spa Requirements-ORP	42. Equip. Change-FBC
11. Diving Board-FBC	EQUIPMENT ROOM	43. Approved Chemicals
12. Pool Cover	26. Wading Pool-Quick Dump	X 44. Maintenance Log
13. Pool Side Shower-FBC	27. Water Level/Control	45. Inspection Posted
POOL SAFETY	28. Disinfection Feeder/Generator	46. Safety-514.0315(2)
14. Life Hook(s) w/Pole	29. pH Feeder	47. Fences/Gates- FBC
15. Life Ring(s) w/Rope	30. Chem. Container Label-FBC	48. Other
16. Safety Line	31. Filter / Pump	49. Other

NOTE: It is unlawful to modify a public pool or its equipment without prior approval from the local building department and submitting an application to DOH.

Inspector Signature:

Matt Ba

Client Signature:

Emailed

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC POOL AND BATHING PLACE
INSPECTION REPORT



2 of 2

General Comments

Note: Recommend pull chain on poolside shower.
Update pool signage to include "POOL MAXIMUM DEPTH: _____ FEET"

Email Address(es): gcabral@agentlink.net

DOH Web Page For Pools: <http://www.floridahealth.gov/environmental-health/swimming-pools/index.html>

Violations Comments

Violation #19. Supplies 64E-10, FAC
Men's restroom without toilet paper and paper towels.
CODE REFERENCE: Supplies. 64E-10. Sanitary facilities must be furnished with toilet tissue, soap, single use paper towels or automatic hand-drying device, and waste receptacle.

Violation #20. Clean 64E-10, FAC
Women's restroom toilet is dirty/toilet paper in bowl - clean
CODE REFERENCE: Clean. 64E-10. Sanitary facilities and floors shall be maintained in a cleaned and disinfected condition.

Violation #44. Maintenance Log
Maintenance log must be filled out daily.
CODE REFERENCE: Maintenance Log. 64E-9.004(10). Daily record must be kept for pH and disinfectant residual tested each day the pool is open for use, and weekly for Cyanuric Acid.

Inspection Conducted By: Matthew Bowen (45622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name:
Date: 2/7/2022

Inspector Signature:

Matthew Bowen

Client Signature:

Emailed